



**JCM 440 All Stainless Steel
Line Stop Sleeve
4" - 8"
INSTALLATION INSTRUCTIONS**

Thoroughly clean pipe surface. Check the size and range of the tapping sleeve to verify correct size product. Check surface of pipe where tapping sleeve will be installed to make certain pipe is free of flaws, gouges and extreme irregularities.

Lubricate pipe and face of gaskets with water or soap-water. **Do not use grease or pipe lubricant.**

Position outlet half of body on pipe making sure outlet is aligned with branch line to be connected. Never position so that rotation is required. Make certain the tapered edges of the gaskets are smooth.

Position back half of body over tapered gasket edges extending from outlet half of body and install bolts.

Tighten outside bolts first, working toward the center. Tighten both top and bottom bolts evenly. Alternate from one side of sleeve to the other. Tighten to the following torque levels:

Rigid pipe (DI, CI, A/C, Steel), C-900/905 PVC, HDPE SDR11 - SDR17

4" - 8" Nominal Pipe Sizes

85 ft. lbs. minimum - 125 ft. lbs. maximum

10" and Larger Nominal Pipe Sizes

100 ft. lbs. minimum - 125 ft. lbs. maximum

Thin wall, flexible, class PVC (SDR 21, 26) pipe

50 ft. lbs. minimum - 55 ft. lbs. maximum

Check inside of sleeve neck to make certain gasket is properly seated and not protruding where tapping cutter may damage it.

Install tapping valve per applicable standards. JCM recommends adherence to the AWWA M-44 Manual. Provide for proper valve and pipe trenching, support, restraint and burial.

Test assembly seals with water (per AWWA C-223) using test plug provided on sleeve or test connection on tapping machine. Note: No more than 10% above line pressure on HDPE or maximum pipe working pressure rating. When assured that all seals are tight and test is completed, re-check bolt torques and proceed with tapping and line stopping operation.

Follow applicable line stop procedures or consult line stop equipment manufacturer.

Note: Size on size tapping cutter must not be larger than recommended by pipe manufacturer. Also, tapping operation must not force the pipe away from the gasket seal.

Note: For care of stainless steel bolts and nuts, see reverse side.

INT440-1205ss



Recommendations For Installation Of Fittings With Stainless Steel Bolts And Nuts

This JCM Quality Fitting is equipped with 18-8 stainless steel bolts and nuts for superior corrosion resistance. It is the nature of stainless steel fasteners to gall and freeze if not properly handled. This undesirable characteristic is due to the inherent properties of the stainless material. The galling and freezing action is often triggered by the presence of metal chips, burrs and grains of sand on the threads of the bolts and nuts.

Extra care has been taken by JCM prior to assembly and packing of this fitting to assure a trouble-free installation.

1. The nuts and bolts are made from material of different hardness so that they have different strengths.
2. The nuts are coated with a special (antiseize) coating.
3. Each nut is assembled by hand to be sure that it went on the bolt freely.
4. The bolts and nuts are handled carefully to avoid damage to the threads.
5. The bolts and nuts are made to exacting specifications to assure that the correct material is used and that the thread form is correct.

However, it must be pointed out that during field installation, the threads **MUST BE KEPT CLEAN AND FREE FROM NICKS.**

When a mild steel or bronze bolt is used, the low ultimate strength of the material allows the nut to tear itself free. Not so with 18-8 Stainless Steel. The ultimate strength of the material is so great, that it increases rapidly with cold work. However, once foreign matter such as a grain of sand wedges the threads, or the thread form is altered by over-torquing, the nuts cannot be removed.

The specially coated nuts supplied by JCM help to eliminate the galling caused by overtorquing, but **the bolts must be kept clean and not pitched or thrown into the tool bucket during installation. Should additional lubrication be required, a Molybdenum-Base lubricant is recommended.**

NOTE: Installation of this fitting with a pneumatic wrench may cause seizure of the nut. **A JCM 901 Master Wrench or JCM 905 Torque Wrench with Deep Socket is recommended.**

INTSSB - 011306